
THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES, ACTUAL INSTALLATION MAY VARY DEPENDING ON INSTALLATION LOCATION AND PARAMETERS AND IT MUSTS BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES, VERIFY WITH LOCAL BUILDINGS OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PRINT OR DESCRIPTION OF H R



TANKLESS QUANTITY: RECOMMENDED PIPE SIZE	1 UNIT: 3/4"   2 UNITS: 1"   3 UNITS: 1-1/4"   4-5 UNITS: 1-1/2"   6-8 UNITS: 2"   9-14 UNITS: 2-1/2"   15-16 UNITS: 3"				SYMBOL LEGEND			
20 GOODYEAR IRVINE, CA 92618 800-519-8794 www.navieninc.com	NHW-AE SERIES TANKLESS WATER HEATER - OUTDOOR UNIT		UNION	FULL-PORT VALVE	PRESSURE RELIEF VALVE	CHECK VALVE		
	(1) NHW-AE TANKLESS WATER HEATER WITH EXTERNAL RECIRCULATION MODE INCLUDES MODELS 160, 180 AND 199		EXPANSION TANK	VALVE	子 VALVE	1 AVEAU		
	DRAWN BY: S. STOEKE	NHW-AE-1-E	JULY 27, 2023					