
THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES. ACTUAL INSTALLATION MAY VARY DEPENDING ON INSTALLATION LOCATION AND PARAMETERS AND IT MUST BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES. VERIFY WITH LOCAL BUILDING OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PRINT OR DESCRIPTION OF NOTION BEFOREMED WITHOUT EXPRESSED WRITTEN PROMISSION BY AVAIEN, INC.



| TANKLESS QUANTITY: RECOMMENDED PIPE SIZE | 1 UNIT: 3/4" 2 UNITS: 1" 3 UNITS: 1-1/4" 4-5 UNITS: 1-1/2" 6-8 UNITS: 2" 9-14 UNITS: 2-1/2" 15-16 UNITS: 3"                      |          |              |               | SYMBOL LEGEND |                 |                             |  |
|--|--|----------|--------------|---------------|---------------|-----------------|-----------------------------|--|
|  | NPE-S2 SERIES TANKLESS WATER HEATER  |          |              | — UNION       | CHECK VALVE   | FULL-PORT VALVE | PRESSURE<br>RELIEF<br>VALVE |  |
| Mavien                                   | (4) NPE-S2 TANKLESS WATER HEATERS (INCLUDES NPE-A2 INTERNAL CIRCULATION MODE) INCLUDES MODELS 150(NPE-S2 ONLY), 180, 210 AND 240 |          |              |               |               |                 |                             |  |
| 20 GOODYEAR                              |  |          |              | CASCADE CABLE |               |                 |                             |  |
| IRVINE, CA 92618<br>800-519-8794         |  |          |              |               |               |                 |                             |  |
| www.navieninc.com                        | DRAWN BY: S. STOEKE  | NPE-S2-4 | MAY 11, 2022 |               |               |                 |                             |  |