
THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES. ACTUAL INSTALLATION MAY VARY DEPENDING ON INSTALLATION LOCATION AND PARAMETERS AND IT MUSTS BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES. VERIFY WITH LOCAL BUILDINGS OFFICIALS BEFORE COMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PPING OR DESIGN IS NOT TO BE PERFORMED WITHOUT EXPRESSED WRITTEN PERMISSION BY NAMEN, INC.



| TAN | KLESS QUANTITY: RECOMMENDED PIPE SIZE | 1 UNIT: 3/4" 2 UNITS: 1" 3 UNITS: 1-1/4" 4-5 UNITS: 1-1/2" 6-8 UNITS: 2" 9-14 UNITS: 2-1/2" 15-16 UNITS: 3" | | | | SYMBOL LEGEND | | | | | |
|--------|---------------------------------------|---|-----|----------|--|---------------|----------|---------------|---------|-----------------|-----------------------|
| | | NPE-S2 SERIES TANKLESS WATER HEATER | | | | | | CASCADE CABLE | — UNION | FULL-PORT VALVE | PRESSURE RELIEF VALVE |
| Mavien | | (5) NPE-S2 TANKLESS WATER HEATERS | | | | | | | | VALVE | イ VALVE |
| | 20 GOODYEAR | (INCLUDES NPE-A2 INTERNAL CIRCULATION MODE) | | | | | | | | | |
| | IRVINE, CA 92618 800-519-8794 | INCLUDES MODELS 150(NPE-S2 ONLY), 180, 210 AND 240 | | | | | | | | | |
| | www.navieninc.com | DRAWN BY: S. STOE | EKE | NPE-S2-5 | | MAY | 12, 2022 | | | | |