
THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES. ACTUAL INSTALLATION MAY VARY DEPENDING ON INSTALLATION LOCATION AND PARAMETERS AND IT MUSTS THE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES. VERREY WITH LOCAL BUILDINGS OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PRINT GO R DESIGN IS NOT TO BE PERFORMED WITHOUT EXPRESSED WITHER INSISION BY NAMEN, INC.



| TANKLESS QUANTITY: RECOMMENDED PIPE SIZE | 1 UNIT: 3/4" 2 UNITS: 1" 3 UNITS: 1-1/4" 4-5 UNITS: 1-1/2" 6-8 UNITS: 2" 9-14 UNITS: 2-1/2" 15-16 UNITS: 3" | | | SYMBOL LEGEND | | | |
|--|---|------------|--------------|---------------|---------|-----------------|-----------------------|
| | NPE-S2 SERIES TANKLESS WATER HEATER | | | CASCADE CABLE | = UNION | FULL-PORT VALVE | PRESSURE RELIEF VALVE |
| Mavien | (7) NPE-S2 TANKLESS WATER HEATERS | | | | | | |
| 20 GOODYEAR | (INCLUDES NPE—A2 INTERNAL CIRCULATION MODE) INCLUDES MODELS 150(NPE—S2 ONLY), 180, 210 AND 240 | | | | | | |
| IRVINE, CA 92618 800-519-8794 | | | | | | | |
| www.navieninc.com | DRAWN BY: S. STOEKE | NPE-S2-7-I | MAY 20, 2021 | | | | |