THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES. ACTUAL INSTALLATION MAY VARY DEPENDING ON INSTALLATION LOCATION AND PARAMETERS AND IT MUST BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES. VERIFY WITH LOCAL BUILDINGS OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PIPING OR DESIGN IS NOT TO BE PERFORMED WITHOUT EXPRESSED WRITTEN PROMISSION BY NAVIEN, INC. DOMESTIC HOT WATER CONDENSATE **HYDRONIC** • FEED WATER DOMESTIC • COLD WATER GAS SYSTEM SUPPLY ₽₩°₽₽ **DHW RECIRCULATION REQUIREMENTS:** * REFER TO NAVIEN I & O MANUAL FOR INSTALLATION REQUIREMENTS AND NOTE: FURTHER INFORMATION. HYDRAULIC **SEPARATOR** SIZED BY **OTHERS SYSTEM** RETURN **OPTIONAL** NAVI-CLEAN SHOWN SYMBOL LEGEND NCB-H SERIES COMBI-BOILER MNavien EXPANSION TANK BACKFLOW PREVENTER FULL-PORT VALVE (1) NCB-H COMBI-BOILER APPLICATION PRESSURI RELIEF VALVE DHW RECIRCULATION SHOWN WITH HYDRAULIC SEPARATOR ---- CONTROL WIRING CIRCULATOR 20 GOODYEAR IRVINE, CA 92618 INCLUDES MODELS NCB-190/060H,190/080H,240/110H,240/130H,250/150H 800-519-8794 NAVICLEAN FILTER · CASCADE CABLE S. STOEKE NCB-H-1-P-DHWR-HS SEPTEMBER 2, 2022 www.navieninc.com