THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES. ACTUAL INSTALLATION MAY VARY DEPENDING ON INSTALLATION LOCATION AND PARAMETERS AND IT MUST BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES. VERIFY WITH LOCAL BUILDINGS OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PIPING OR DESIGN IS NOT TO BE PERFORMED WITHOUT EXPRESSED WRITTEN PROMISSION BY MANEN, INC. SYSTEM **SUPPLY** RETURN **SYSTEM** SUPPLY(S) **SENSOR SENSOR** RETURN(S) 12" MAX NHB—H UNIT CAN INTERNALLY CONTROL UP TO 3 ZONE CIRCULATORS PER BOILER, WITHOUT A ZONE CONTROL PANEL INSTALLED. ANY ADDITIONAL ZONES SHALL REQUIRE A CIRC ZONE PANEL. REFER TO NAVIEN I & O MANUAL FOR ADDITIONAL INFORMATION. **BOILER** BOILER **BOILER BOILER BOILER** #3 **HYDRONIC** FEED •— 1841 14 14 1841 WATER GAS CONDENSATE SYMBOL LEGEND FULL-PORT VALVE EXPANSION TANK BACKFLOW PREVENTER NHB-H SERIES BOILER PRESSURI RELIEF VALVE MNavien THERMOSTAT CIRCULATOR (5) NHB-H BOILERS WITH OUTDOOR TEMPERATURE SENSOR BALL DRAIN VALVE AIR ELIMINATION COMMON SECONDARY INJECTION PIPING 20 GOODYEAR =UNION IRVINE, CA 92618 INCLUDES MODELS NHB-110H, 150H 800-519-8794 PRESSURE REDUCING VALVE WYE STRAINER
W/ BLOWDOWN S. STOEKE NHB-H-5-ZP-MULT-C JANUARY 25, 2024 www.navieninc.com